

Technical drawing of a cable tray assembly. The drawing shows a cross-section of a cable tray with a cable bundle. The cable bundle is labeled *ACБ-6 3x95*. The tray is labeled *TM 21-1600/10-4X/11*. The tray is supported by a structure labeled *ПБЗ-10/630*. Dimensions are indicated: 1370 (width of the tray), 800 (height of the tray), and 1370 (width of the support structure). The drawing is oriented vertically, with the cable bundle at the top and the support structure at the bottom. The drawing is labeled with a reference number *2* at the bottom left and a note *+3500** at the bottom right.

Technical drawing of a cable tray system in a room. The drawing shows a cable tray (Шина АЛ 100x10) supported by a bracket (ПБЗ-10/630) on a wall. The tray is connected to a cable (АСБ-6 3x95) that runs down to a cable tray (ТМГ 21-1600/10-4X11) on the floor. The drawing includes elevation markers: +3.500* for the wall bracket, +4.080* for the ceiling, and 0.000 for the floor. A section line '2' is shown on the left.

- | | | | | | | | | |
|-----------|------------------|-------|------|--|--|-----------|--------|---------|
| | | | | | | ЭН22-500 | | |
| Изм./Лист | № докум. | Подп. | Дата | Установка силовых трансформаторов
электропитания термического участка
цеха №18 (Корпус 2) в ТП-9, ТП-10. | | Лит. | Масса | Масштаб |
| Разраб. | Романов С.А. | | | | | | | |
| Проб. | Романов С.А. | | | | | | | |
| Т.контр. | | | | План размещения
оборудования в ТП-12 | | Лист | Листов | |
| Н.контр. | | | | | | | | |
| Утв. | Меляшинский А.В. | | | Копировал | | Формат А2 | | |